

White City WTP										
December 2022	Raw Volume (m3) Avg	Treated Volume (m3) Avg	Treated Free Chlorine (mg/L) Min	Treated Total Chlorine (mg/L) Min	Treated Free Chlorine (Analyser) (mg/L) Min	Treated pH (Analyser) (pH units) Avg	Treated Turbidity (NTU) Max	Treated Turbidity (Analyser) (NTU) Max	Treated Iron (mg/L) Avg	Treated Manganese (mg/L) Avg
Dec 01	788	733	0.80	1.13	0.88	7.18	0.18	0.046		0.013
02	593	593	0.78	1.13	0.87	7.18	0.15	0.044		0.019
03	528	563	0.79	1.11	0.80	7.20	0.15	0.043		0.013
04	1005	834	0.82	1.17	0.84	7.18	0.13	0.047		0.014
05	779	684	0.80	1.19	0.87	7.17	0.17	0.045	0.00	0.039
06	599	582	0.82	1.19	0.89	7.17	0.11	0.042		0.014
07	559	617	0.85	1.18	0.89	7.17	0.11	0.043		0.028
08	847	676	0.93	1.25	0.93	7.17	0.10	0.049		0.019
09	632	640	0.93	1.28	0.93	7.17	0.10	0.050		0.020
10	760	716	0.92	1.29	0.95	7.18	0.11	0.048	0.00	0.018
11	712	711	0.93	1.33	0.97	7.17	0.10	0.047	0.00	0.021
12	795	635	0.97	1.36	1.00	7.17	0.09	0.042	0.00	0.013
13	698	677	0.97	1.29	0.99	7.14	0.11	0.039		0.025
14	715	640	0.93	1.31	0.97	7.15	0.10	0.036		0.020
15	545	585	0.94	1.33	0.96	7.15	0.10	0.034		0.017
16	877	670	0.99	1.29	0.99	7.17	0.09	0.038		0.019
17	662	720	0.93	1.36	0.98	7.17	0.09	0.043		0.019
18	550	517	0.96	1.34	0.98	7.17	0.09	0.044		0.019
19	981	883	1.01	1.35	0.99	7.18	0.10	0.044	0.00	0.018
20	588	542	0.91	1.27	0.97	7.17	0.12	0.048		
21	684	683	0.90	1.26	0.94	7.17	0.10	0.050		0.025
22	658	616	0.84	1.23	0.89	7.17	0.13	0.052		0.011
23	810	799	0.86	1.20	0.86	7.17	0.11	0.051	0.01	0.014
24	792	691	0.82	1.17	0.84	7.17	0.12	0.052	0.01	0.026
25	578	508	0.82	1.14	0.82	7.17	0.15	0.054		0.014
26	745	626	0.81	1.09	0.79	7.17	0.18	0.052	0.00	0.010
27	558	612	0.75	1.08	0.76	7.14	0.17	0.051	0.00	0.006
28	839	740	0.82	1.14	0.77	7.14	0.11	0.051		0.010
29	587	581	0.76	1.10	0.80	7.15	0.10	0.054		0.013
30	846	771	0.79	1.14	0.81	7.15	0.10	0.049		0.010
31	657	640	0.80	1.13	0.82	7.15	0.13	0.050		0.005
Minimum	528	508	0.75	1.08	0.76	7.14	0.09	0.034	0.00	0.005
Maximum	1005	883	1.01	1.36	1.00	7.20	0.18	0.054	0.01	0.039
Average	709	661	0.87	1.22	0.90	7.17	0.12	0.046	0.00	0.017
Count			31	31	31	31	31	31	9	30
Total	21967	20485								
95th Percentile							0.18	0.054		
Exceedences			0		0					

If there is more than one per day reading for free chlorine residual, the daily minimum is reported.

If there is more than one per day reading for turbidity, the daily maximum is reported.

White City WTP - Bacteriological (Raw Water)			
December 2022	Total Coliform (Count)	E. Coli (Count)	Background Bacteria (Count)
Dec 05	0	0	0

White City WTP - Bacteriological						
December 2022	Total Coliform (Count)	E. Coli (Count)	Background Bacteria (Count)	Free Chlorine (mg/L)	Total Chlorine (mg/L)	Turbidity (NTU)
Dec 05	0	0	0	0.80	1.19	0.17
Dec 12	0	0	0	0.97	1.36	0.09
Dec 19	0	0	0	1.01	1.35	0.10
Dec 28	0	0	0	0.82	1.14	0.11
Minimum				0.80	1.14	0.09
Maximum	0	0	0	1.01	1.36	0.17
Average				0.90	1.26	0.12
Count	4	4	4	4	4	4
Exceedences	0	0	0	0	0	

A minimum of 0.10 mg/L free chlorine residual **OR** 0.50 mg/L total chlorine residual is required in each bacteriological sample.

White City Distribution - Bacteriological							
December 2022	Sampling Location ()	Total Coliform (Count)	E. Coli (Count)	Background Bacteria (Count)	Free Chlorine (mg/L)	Total Chlorine (mg/L)	Turbidity (NTU)
Dec 05	Town Shop	0	0	0	0.31	0.39	0.14
Dec 12	WC School	0	0	0	0.92	1.31	0.12
Dec 19	post office	0	0	0	0.95	1.28	0.17
Dec 28	townshop	0	0	0	0.74	1.03	0.11
Minimum					0.31	0.39	0.11
Maximum		0	0	0	0.95	1.31	0.17
Average					0.73	1.00	0.14
Count		4	4	4	4	4	4
Exceedences		0	0	0	0	1	

A minimum of 0.10 mg/L free chlorine residual **OR** 0.50 mg/L total chlorine residual is required in each bacteriological sample.

Environmental Services Analysis Report - Final

Invoice Number: 3423008	Collected Date: 05-Dec-2022 1:45 PM
Sample Location: Town Shop	Received: 05-Dec-2022 3:57 PM
Collected by: B. Stevenson	Reported: 06-Dec-2022 2:08 PM
Station #: SK05JF0022	Water Source: Distributed

Submitted By:

SASK WATER
225 A HELLEN DRIVE
RM OF SHERWOOD, SK
S4K 0A3

Invoice:

SASK WATER
225 A HELLEN DRIVE
RM OF SHERWOOD, SK
S4K 0A3

Analysis	Result	Unit	Sask Guideline	Test Comment	Fee
Regular Panel					23.00
Total Coliform	No Detectable	orgs/100 mL	No orgs/100 mL	1	
E. Coli	No Detectable	orgs/100 mL	No orgs/100 mL	2	

Submitter Phone Number: 306-533-1936

Emailed results to: ReginaEastResults@saskwater.com

Comments:

1. Testing result indicates that your water meets the Bacteriological standard for Canadian drinking water quality.
2. See above for comment

Please include
Invoice Number
with payment
and remit to:

Saskatchewan Health Authority
c/o Finance
2180 23rd Avenue
Regina, Saskatchewan
S4S 0A5

Total Fees (including GST) 23.00

Tax Summary 1.10
G.S.T. (reg # 89583 0180 RT001)

Amount Received: (No Payment Received) 0.00

Balance Due upon receipt of invoice.

Balance Owed	\$23.00
---------------------	----------------

Contact Us:

Result Interpretation: Please contact your EPO for advice or phone 306-535-4347
Billing Inquiries: Phone: 1-833-989-5353, Email: shaar@saskhealthauthority.ca

The following data was provided by the submitter. The Environmental Services Lab does not guarantee the accuracy of the results.

Free Chlorine:	0.31	Total Chlorine:	0.39	Turbidity:	0.14
----------------	------	-----------------	------	------------	------

Environmental Services Analysis Report - Final

Invoice Number: 3423534	Collected Date: 12-Dec-2022 11:35 AM
Sample Location: WC School	Received: 12-Dec-2022 4:03 PM
Collected by: Brendan Liggett	Reported: 13-Dec-2022 2:26 PM
Station #: SK05JF0022	Water Source: Distributed
Permit: 2574	
WHITE CITY DIST.SYSTEM	

Submitted By:

SASK WATER
225 A HELLEN DRIVE
RM OF SHERWOOD, SK
S4K 0A3

Invoice:

SASK WATER
225 A HELLEN DRIVE
RM OF SHERWOOD, SK
S4K 0A3

Analysis	Result	Unit	Sask Guideline	Test Comment	Fee
Regular Panel					23.00
Total Coliform	No Detectable	orgs/100 mL	No orgs/100 mL	1	
E. Coli	No Detectable	orgs/100 mL	No orgs/100 mL	2	

Submitter Phone Number: 306-533-1936

Emailed results to: ReginaEastResults@saskwater.com

Comments:

1. Testing result indicates that your water meets the Bacteriological standard for Canadian drinking water quality.
2. See above for comment

Please include
Invoice Number
with payment
and remit to:

Saskatchewan Health Authority
c/o Finance
2180 23rd Avenue
Regina, Saskatchewan
S4S 0A5

Total Fees (including GST) 23.00

Tax Summary 1.10
G.S.T. (reg # 89583 0180 RT001)

Amount Received: (No Payment Received) 0.00

Balance Due upon receipt of invoice.

Balance Owed	\$23.00
---------------------	----------------

Contact Us:

Result Interpretation: Please contact your EPO for advice or phone 306-535-4347
Billing Inquiries: Phone: 1-833-989-5353, Email: shaar@saskhealthauthority.ca

The following data was provided by the submitter. The Environmental Services Lab does not guarantee the accuracy of the results.

Free Chlorine:	0.92	Total Chlorine:	1.31	Turbidity:	0.12
----------------	------	-----------------	------	------------	------

Environmental Services Analysis Report - Final

Invoice Number: 3424120	Collected Date: 19-Dec-2022 2:00 PM
Sample Location: Post Office	Received: 20-Dec-2022 10:36 AM
Collected by: N Hodges	Reported: 21-Dec-2022 9:40 AM
Station #: SK05JF0022	Water Source: Distributed
Permit: 2574	
WHITE CITY DIST.SYSTEM	

Submitted By:

SASK WATER
225 A HELLEN DRIVE
RM OF SHERWOOD, SK
S4K 0A3

Invoice:

SASK WATER
225 A HELLEN DRIVE
RM OF SHERWOOD, SK
S4K 0A3

Analysis	Result	Unit	Sask Guideline	Test Comment	Fee
Regular Panel					23.00
Total Coliform	No Detectable	orgs/100 mL	No orgs/100 mL	1	
E. Coli	No Detectable	orgs/100 mL	No orgs/100 mL	2	

Submitter Phone Number: 306-533-1936

Emailed results to: ReginaEastResults@saskwater.com

Comments:

1. Testing result indicates that your water meets the Bacteriological standard for Canadian drinking water quality.
2. See above for comment

Please include
Invoice Number
with payment
and remit to:

Saskatchewan Health Authority
c/o Finance
2180 23rd Avenue
Regina, Saskatchewan
S4S 0A5

Total Fees (including GST) 23.00

Tax Summary 1.10
G.S.T. (reg # 89583 0180 RT001)

Amount Received: (No Payment Received) 0.00

Balance Due upon receipt of invoice.

Balance Owed	\$23.00
---------------------	----------------

Contact Us:

Result Interpretation: Please contact your EPO for advice or phone 306-535-4347
Billing Inquiries: Phone: 1-833-989-5353, Email: shaar@saskhealthauthority.ca

The following data was provided by the submitter. The Environmental Services Lab does not guarantee the accuracy of the results.

Free Chlorine:	0.95	Total Chlorine:	1.28	Turbidity:	0.17
----------------	------	-----------------	------	------------	------

Environmental Services Analysis Report - Final

Invoice Number: 3424487	Collected Date: 28-Dec-2022 10:37 AM
Sample Location: White City Town Shop	Received: 28-Dec-2022 2:20 PM
Collected by: BSTE	Reported: 29-Dec-2022 2:12 PM
Station #: SK05JF0022	Water Source: Distributed
Permit: 2574	
WHITE CITY DIST.SYSTEM	

Submitted By:

SASK WATER
225 A HELLEN DRIVE
RM OF SHERWOOD, SK
S4K 0A3

Invoice:

SASK WATER
225 A HELLEN DRIVE
RM OF SHERWOOD, SK
S4K 0A3

Analysis	Result	Unit	Sask Guideline	Test Comment	Fee
Regular Panel					23.00
Total Coliform	No Detectable	orgs/100 mL	No orgs/100 mL	1	
E. Coli	No Detectable	orgs/100 mL	No orgs/100 mL	2	

Submitter Phone Number: 306-533-1936

Emailed results to: ReginaEastResults@saskwater.com

Comments:

1. Testing result indicates that your water meets the Bacteriological standard for Canadian drinking water quality.
2. See above for comment

Please include
Invoice Number
with payment
and remit to:

Saskatchewan Health Authority
c/o Finance
2180 23rd Avenue
Regina, Saskatchewan
S4S 0A5

Total Fees (including GST) 23.00

Tax Summary 1.10
G.S.T. (reg # 89583 0180 RT001)

Amount Received: (No Payment Received) 0.00

Balance Due upon receipt of invoice.

Balance Owed	\$23.00
---------------------	----------------

Contact Us:

Result Interpretation: Please contact your EPO for advice or phone 306-535-4347
Billing Inquiries: Phone: 1-833-989-5353, Email: shaar@saskhealthauthority.ca

The following data was provided by the submitter. The Environmental Services Lab does not guarantee the accuracy of the results.

Free Chlorine:	.74	Total Chlorine:	1.03	Turbidity:	.11
----------------	-----	-----------------	------	------------	-----