

White City WTP										
October 2022	Raw Volume (m3) Avg	Treated Volume (m3) Avg	Treated Free Chlorine (mg/L) Min	Treated Total Chlorine (mg/L) Min	Treated Free Chlorine (Analyser) (mg/L) Min	Treated pH (Analyser) (pH units) Avg	Treated Turbidity (NTU) Max	Treated Turbidity (Analyser) (NTU) Max	Treated Iron (mg/L) Avg	Treated Manganese (mg/L) Avg
Oct 01	1014	1000	0.91	1.23	0.95	7.13	0.16	0.042	0.04	0.017
02	931	829	0.89	1.22	0.92	7.13	0.17	0.041	0.01	0.017
03	1366	1273	0.94	1.22	0.90	7.13	0.18	0.042	0.01	0.010
04	1121	1076	0.86	1.17	0.89	7.13	0.19	0.041	0.02	0.014
05	910	952	0.81	1.10	0.87	7.13	0.19	0.042		0.015
06	912	754	0.83	1.02	0.86	7.13	0.19	0.040		0.031
07	841	764	0.82	1.13	0.85	7.14	0.18	0.037		0.025
08	695	568	0.82	1.12	0.84	7.14	0.24	0.041		0.014
09	725	803	0.80	1.12	0.82	7.14	0.21	0.039		0.017
10	965	841	0.81	1.00	0.84	7.14	0.22	0.039	0.00	0.030
11	1045	1046	0.95	1.14	0.90	7.14	0.21	0.039		0.022
12	697	695	0.86	1.18	0.91	7.14	0.21	0.042	0.00	0.010
13	854	677	0.82	1.13	0.91	7.14	0.21	0.037		0.015
14	617	610	0.76	1.15	0.90	7.14	0.20	0.041		0.011
15	637	543	0.84	1.18	0.79	7.14	0.19	0.038	0.01	0.012
16	738	689	0.84	1.17	0.78	7.14	0.16	0.037	0.01	0.010
17	923	909	0.88	1.19	0.80	7.14	0.17	0.040	0.01	0.010
18	676	670	0.85	1.19	0.79	7.15	0.19	0.038	0.00	0.007
19	800	693	0.81	1.11	0.78	7.15	0.19	0.035		0.030
20	623	654	0.71	1.01	0.77	7.15	0.21	0.036		0.016
21	863	701	0.84	1.16	0.78	7.15	0.28	0.037		0.011
22	680	708	0.84	1.17	0.76	7.15	0.15	0.039		0.011
23	640	510	0.86	1.12	0.75	7.15	0.15	0.038		0.021
24	576	876	0.84	1.16	0.75	7.15	0.15	0.035	0.01	0.014
25	442	556	0.68	1.07	0.75	7.15	0.18	0.038		0.028
26	447	647	0.79	1.12	0.74	7.15	0.16	0.038		0.026
27	810	698	0.82	1.13	0.73	7.15	0.15	0.036		0.022
28	538	611	0.81	1.15	0.74	7.14	0.15	0.035		0.034
29	926	713	0.83	1.13	0.70	7.13	0.18	0.035	0.00	0.020
30	574	479	0.77	1.10	0.66	7.11	0.14	0.031	0.00	0.017
31	842	916	0.72	1.02	0.62	7.10	0.13	0.028	0.03	0.024
Minimum	442	479	0.68	1.00	0.62	7.10	0.13	0.028	0.00	0.007
Maximum	1366	1273	0.95	1.23	0.95	7.15	0.28	0.042	0.04	0.034
Average	788	757	0.83	1.13	0.81	7.14	0.18	0.038	0.01	0.018
Count			31	31	31	31	31	31	14	31
Total	24428	23461								
95th Percentile							0.22	0.042		
Exceedences			0		0					

If there is more than one per day reading for free chlorine residual, the daily minimum is reported.

If there is more than one per day reading for turbidity, the daily maximum is reported.

White City WTP - Bacteriological						
October 2022	Total Coliform (Count)	E. Coli (Count)	Background Bacteria (Count)	Free Chlorine (mg/L)	Total Chlorine (mg/L)	Turbidity (NTU)
Oct 03	0	0	0	0.94	1.22	0.18
Oct 11	0	0	0	0.95	1.14	0.21
Oct 17	0	0	0	0.88	1.19	0.17
Oct 24	0	0	0	0.84	1.16	0.15
Oct 31	0	0	0	0.72	1.02	0.13
Minimum				0.72	1.02	0.13
Maximum	0	0	0	0.95	1.22	0.21
Average				0.87	1.15	0.17
Count	5	5	5	5	5	5
Exceedences	0	0	0	0	0	

A minimum of 0.10 mg/L free chlorine residual **OR** 0.50 mg/L total chlorine residual is required in each bacteriological sample.

White City Distribution - Bacteriological							
October 2022	Sampling Location ()	Total Coliform (Count)	E. Coli (Count)	Background Bacteria (Count)	Free Chlorine (mg/L)	Total Chlorine (mg/L)	Turbidity (NTU)
Oct 03	PostOffice	0	0	0	0.79	1.07	0.22
Oct 11	TownShop	0	0	0	0.80	1.12	0.26
Oct 17	School	0	0	0	0.81	0.96	0.19
Oct 24	townshop	0	0	0	0.82	1.12	0.16
Oct 31	ER School	0	0	0	0.71	0.94	0.14
Minimum					0.71	0.94	0.14
Maximum		0	0	0	0.82	1.12	0.26
Average					0.79	1.04	0.19
Count		5	5	5	5	5	5
Exceedences		0	0	0	0	0	

A minimum of 0.10 mg/L free chlorine residual **OR** 0.50 mg/L total chlorine residual is required in each bacteriological sample.

SUC 2537

(306) 787-7138 / (306) 787-3140

Environmental Services Analysis Report - Final

Invoice Number:	3418586	Collected Date:	03-Oct-2022 10:52 AM
Sample Location:	White City Post Office	Received:	03-Oct-2022 3:34 PM
Collected by:	BSTE	Reported:	04-Oct-2022 2:30 PM
Station #:	SK05JF0022	Water Source:	Distributed
	WHITE CITY DIST.SYSTEM		

Submitted By: SASK WATER 225 A HELLEN DRIVE RM OF SHERWOOD, SK S4K 0A3	Invoice: SASK WATER 225 A HELLEN DRIVE RM OF SHERWOOD, SK S4K 0A3
---	--

Analysis	Result	Unit	Sask Guideline	Test Comment	Fee
Regular Panel					23.00
Total Coliform	No Detectable	orgs/100 mL	No orgs/100 mL	1	
E. Coli	No Detectable	orgs/100 mL	No orgs/100 mL	2	

Submitter Phone Number: 306-533-1936	Emailed results to: ReginaEastResults@saskwater.com
---	--

Comments:

1. Testing result indicates that your water meets the Bacteriological standard for Canadian drinking water quality.
2. See above for comment

Please include Invoice Number with payment and remit to:	Saskatchewan Health Authority c/o Finance 2180 23rd Avenue Regina, Saskatchewan S4S 0A5	Total Fees (including GST) 23.00 Tax Summary 1.10 G.S.T. (reg # 89583 0180 RT001)
---	--	---

Amount Received: (No Payment Received) 0.00

Balance Due upon receipt of invoice.

Balance Owed	\$23.00
---------------------	----------------

Contact Us:

Result Interpretation: Please contact your EPO for advice or phone 306-535-4347
Billing Inquiries: Phone: (306) 766-5832, Fax: (306) 766-5188, Email: corpfinance@rqhealth.ca

The following data was provided by the submitter. The Environmental Services Lab does not guarantee the accuracy of the results.

Free Chlorine: 0.79	Total Chlorine: 1.07	Turbidity: 0.22
---------------------	----------------------	-----------------

SWC 002611

(306) 787-7138 / (306) 787-3140

Environmental Services Analysis Report - Final

Invoice Number: 3419138	Collected Date: 11-Oct-2022 9:00 AM	
Sample Location: Town Shop	Received: 11-Oct-2022 4:28 PM	
Collected by: N. Matts	Reported: 12-Oct-2022 2:17 PM	
Station #: SK05JF0022	Water Source: Distributed	
Permit: 2574	WHITE CITY DIST.SYSTEM	

Submitted By:

SASK WATER
225 A HELLEN DRIVE
RM OF SHERWOOD, SK
S4K 0A3

Invoice:

SASK WATER
225 A HELLEN DRIVE
RM OF SHERWOOD, SK
S4K 0A3

Analysis	Result	Unit	Sask Guideline	Test Comment	Fee
Regular Panel					23.00
Total Coliform	No Detectable	orgs/100 mL	No orgs/100 mL	1	
E. Coli	No Detectable	orgs/100 mL	No orgs/100 mL	2	

Submitter Phone Number: 306-533-1936

Emailed results to: ReginaEastResults@saskwater.com

Comments:

1. Testing result indicates that your water meets the Bacteriological standard for Canadian drinking water quality.
2. See above for comment

Please include
Invoice Number
with payment
and remit to:

**Saskatchewan Health Authority
c/o Finance
2180 23rd Avenue
Regina, Saskatchewan
S4S 0A5**

Total Fees (including GST)	23.00
Tax Summary	1.10
G.S.T. (reg # 89583 0180 RT001)	
Amount Received: (No Payment Received)	0.00

Balance Due upon receipt of invoice.

Balance Owed	\$23.00
---------------------	----------------

Contact Us:

Result Interpretation: Please contact your EPO for advice or phone 306-535-4347

Billing Inquiries: Phone: (306) 766-5832, Fax: (306) 766-5188, Email: corpfinance@rqhealth.ca

The following data was provided by the submitter. The Environmental Services Lab does not guarantee the accuracy of the results.

Free Chlorine:	.80	Total Chlorine:	1.12	Turbidity:	.26
----------------	-----	-----------------	------	------------	-----

SJC002644

(306) 787-7138 / (306) 787-3140

Environmental Services Analysis Report - Final

Invoice Number: 3419634	Collected Date: 17-Oct-2022 11:07 AM	
Sample Location: White City School	Received: 17-Oct-2022 3:35 PM	
Collected by: BSTE	Reported: 18-Oct-2022 2:32 PM	
Station #: SK05JF0022	Water Source: Distributed	
Permit: 2574	WHITE CITY DIST.SYSTEM	

Submitted By:

SASK WATER
225 A HELLEN DRIVE
RM OF SHERWOOD, SK
S4K 0A3

Invoice:

SASK WATER
225 A HELLEN DRIVE
RM OF SHERWOOD, SK
S4K 0A3

Analysis	Result	Unit	Sask Guideline	Test Comment	Fee
Regular Panel					23.00
Total Coliform	No Detectable	orgs/100 mL	No orgs/100 mL	1	
E. Coli	No Detectable	orgs/100 mL	No orgs/100 mL	2	

Submitter Phone Number: 306-533-1936

Emailed results to: ReginaEastResults@saskwater.com

Comments:

1. Testing result indicates that your water meets the Bacteriological standard for Canadian drinking water quality.
2. See above for comment

Please include
Invoice Number
with payment
and remit to:

**Saskatchewan Health Authority
c/o Finance
2180 23rd Avenue
Regina, Saskatchewan
S4S 0A5**

Total Fees (including GST)	23.00
Tax Summary	1.10
G.S.T. (reg # 89583 0180 RT001)	
Amount Received: (No Payment Received)	0.00

Balance Due upon receipt of invoice.

Balance Owed
\$23.00
Contact Us:

Result Interpretation: Please contact your EPO for advice or phone 306-535-4347
Billing Inquiries: Phone: (306) 766-5832, Fax: (306) 766-5188, Email: corpfinance@rqhealth.ca

The following data was provided by the submitter. The Environmental Services Lab does not guarantee the accuracy of the results.

Free Chlorine:	0.81	Total Chlorine:	0.98	Turbidity:	0.19
----------------	------	-----------------	------	------------	------

SUC2674

Environmental Services Analysis Report - Final

Invoice Number: 3420171
Sample Location: Town Shop
Collected by: N. Hodges
Station #: SK05JF0022

Permit: 2574
WHITE CITY DIST.SYSTEM

Collected Date: 24-Oct-2022 1:00 PM
Received: 24-Oct-2022 4:28 PM
Reported: 25-Oct-2022 2:10 PM
Water Source: Distributed

Submitted By:

SASK WATER
225 A HELLEN DRIVE
RM OF SHERWOOD, SK
S4K 0A3

Invoice:

SASK WATER
225 A HELLEN DRIVE
RM OF SHERWOOD, SK
S4K 0A3

Analysis	Result	Unit	Sask Guideline	Test Comment	Fee
Regular Panel					23.00
Total Coliform	No Detectable	orgs/100 mL	No orgs/100 mL	1	
E. Coli	No Detectable	orgs/100 mL	No orgs/100 mL	2	

Submitter Phone Number: 306-533-1936

Emailed results to: ReginaEastResults@saskwater.com

Comments:

1. Testing result indicates that your water meets the Bacteriological standard for Canadian drinking water quality.
2. See above for comment

Please include
Invoice Number
with payment
and remit to:

Saskatchewan Health Authority
c/o Finance
2180 23rd Avenue
Regina, Saskatchewan
S4S 0A5

Total Fees (including GST)	23.00
Tax Summary	1.10
G.S.T. (reg # 89583 0180 RT001)	
Amount Received: (No Payment Received)	0.00

Balance Due upon receipt of invoice.

Balance Owed	\$23.00
---------------------	----------------

Contact Us:
Result Interpretation: Please contact your EPO for advice or phone 306-535-4347
Billing Inquiries: Phone: (306) 766-5832, Fax: (306) 766-5188, Email: corpfinance@rqhealth.ca

The following data was provided by the submitter. The Environmental Services Lab does not guarantee the accuracy of the results.

Free Chlorine:	.82	Total Chlorine:	1.12	Turbidity:	.16
----------------	-----	-----------------	------	------------	-----

SUC002732

Environmental Services Analysis Report - Final

Invoice Number: 3420682	Collected Date: 31-Oct-2022 11:40 AM	
Sample Location: Emerald Ridge School	Received: 31-Oct-2022 3:41 PM	
Collected by: Brendan Liggett	Reported: 01-Nov-2022 2:09 PM	
Station #: SK05JF0022	Water Source: Distributed	
Permit: 2574		
WHITE CITY DIST.SYSTEM		

Submitted By:

SASK WATER
225 A HELLEN DRIVE
RM OF SHERWOOD, SK
S4K 0A3

Invoice:

SASK WATER
225 A HELLEN DRIVE
RM OF SHERWOOD, SK
S4K 0A3

Analysis	Result	Unit	Sask Guideline	Test Comment	Fee
Regular Panel					23.00
Total Coliform	No Detectable	orgs/100 mL	No orgs/100 mL	1	
E. Coli	No Detectable	orgs/100 mL	No orgs/100 mL	2	

Submitter Phone Number: 306-533-1936

Emailed results to: ReginaEastResults@saskwater.com

Comments:

1. Testing result indicates that your water meets the Bacteriological standard for Canadian drinking water quality.
2. See above for comment

Please include
Invoice Number
with payment
and remit to:

**Saskatchewan Health Authority
c/o Finance
2180 23rd Avenue
Regina, Saskatchewan
S4S 0A5**

Total Fees (including GST)	23.00
Tax Summary	1.10
G.S.T. (reg # 89583 0180 RT001)	
Amount Received: (No Payment Received)	0.00

Balance Due upon receipt of invoice.

Balance Owed	\$23.00
---------------------	----------------

Contact Us:

Result Interpretation: Please contact your EPO for advice or phone 306-535-4347

Billing Inquiries: Phone: (306) 766-5832, Fax: (306) 766-5188, Email: corpfinance@rqhealth.ca

The following data was provided by the submitter. The Environmental Services Lab does not guarantee the accuracy of the results.

Free Chlorine:	0.71	Total Chlorine:	0.94	Turbidity:	0.14
----------------	------	-----------------	------	------------	------