

White City WTP										
October 2023	Raw Volume (m3) Avg	Treated Volume (m3) Avg	Treated Free Chlorine (mg/L) Min	Treated Total Chlorine (mg/L) Min	Treated Free Chlorine (Analyser) (mg/L) Min	Treated pH (Analyser) (pH units) Avg	Treated Turbidity (NTU) Max	Treated Turbidity (Analyser) (NTU) Max	Treated Iron (mg/L) Avg	Treated Manganese (mg/L) Avg
Oct 01	1049	946	1.12	1.61	1.08	7.13	0.09	0.037		0.019
02	1107	1026	1.09	1.54	1.09	7.13	0.07	0.038	0.01	0.019
03	880	858	1.07	1.53	1.08	7.13	0.09	0.041		0.017
04	643	735	1.06	1.51	1.04	7.13	0.06	0.036		0.012
05	1011	784	1.03	1.39	0.98	7.13	0.07	0.039		0.018
06	566	617	0.94	1.37	0.96	7.13	0.08	0.039		0.019
07	538	498	0.92	1.28	0.93	7.14	0.07	0.037		0.040
08	737	718	0.88	1.33	0.90	7.14	0.07	0.038		0.040
09	1109	1050	0.89	1.32	0.91	7.13	0.08	0.038	0.01	0.033
10	659	641	0.92	1.25	0.92	7.13	0.08	0.037		0.018
11	765	703	0.80	1.31	0.92	7.13	0.12	0.034		0.030
12	695	686	0.92	1.28	0.90	7.13	0.07	0.033		0.016
13	793	666	0.82	1.32	0.89	7.13	0.06	0.031		0.018
14	479	503	0.87	1.30	0.89	7.13	0.07	0.031		0.021
15	859	744	0.91	1.33	0.93	7.14	0.07	0.031		0.015
16	1053	868	1.05	1.45	1.06	7.14	0.08	0.031	0.03	0.017
17	527	667	1.12	1.56	1.10	7.14	0.08	0.033		0.019
18	697	704	1.06	1.59	1.11	7.13	0.05	0.030		0.009
19	715	679	1.07	1.52	1.09	7.14	0.07	0.029		0.027
20	787	643	1.03	1.43	1.05	7.14	0.07	0.029		0.007
21	706	720	1.01	1.49	1.03	7.13	0.10	0.029		0.019
22	527	518	1.02	1.50	1.03	7.13	0.08	0.031		0.027
23	1102	1015	1.08	1.53	1.04	7.14	0.06	0.029	0.00	0.023
24	650	594	1.01	1.55	1.05	7.14	0.07	0.030		0.021
25	806	672	1.06	1.50	1.03	7.13	0.07	0.030		0.015
26	392	493	1.05	1.44	1.00	7.14	0.06	0.030		0.009
27	775	676	1.00	1.37	0.97	7.14	0.11	0.030		0.007
28	673	692	0.96	1.35	0.95	7.14	0.05	0.030		0.019
29	796	678	0.97	1.37	0.93	7.14	0.05	0.030		0.007
30	578	560	0.99	1.34	0.94	7.14	0.06	0.030	0.01	0.009
31	791	703	0.91	1.37	0.93	7.14	0.09	0.031		0.017
Minimum	392	493	0.80	1.25	0.89	7.13	0.05	0.029	0.00	0.007
Maximum	1109	1050	1.12	1.61	1.11	7.14	0.12	0.041	0.03	0.040
Average	757	712	0.99	1.42	0.99	7.13	0.07	0.033	0.01	0.019
Count			31	31	31	31	31	31	5	31
Total	23465	22057								
95th Percentile							0.10	0.039		
Exceedences			0		0					

If there is more than one per day reading for free chlorine residual, the daily minimum is reported.

If there is more than one per day reading for turbidity, the daily maximum is reported.

White City WTP - Bacteriological (Raw Water)			
October 2023	Total Coliform (Count)	E. Coli (Count)	Background Bacteria (Count)
Oct 02	0	0	0

White City WTP - Bacteriological						
October 2023	Total Coliform (Count)	E. Coli (Count)	Background Bacteria (Count)	Free Chlorine (mg/L)	Total Chlorine (mg/L)	Turbidity (NTU)
Oct 02	0	0	0	1.13	1.54	0.07
Oct 10	0	0	0	0.92	1.25	0.08
Oct 16	0	0	0	1.05	1.45	0.08
Oct 23	0	0	0	1.08	1.53	0.06
Oct 30	0	0	0	0.99	1.34	0.06
Minimum				0.92	1.25	0.06
Maximum	0	0	0	1.13	1.54	0.08
Average				1.03	1.42	0.07
Count	5	5	5	5	5	5
Exceedences	0	0	0	0	0	

A minimum of 0.10 mg/L free chlorine residual **OR** 0.50 mg/L total chlorine residual is required in each bacteriological sample.

White City Distribution - Bacteriological							
October 2023	Sampling Location ()	Total Coliform (Count)	E. Coli (Count)	Background Bacteria (Count)	Free Chlorine (mg/L)	Total Chlorine (mg/L)	Turbidity (NTU)
Oct 02	TownShop	0	0	0	1.11	1.54	0.07
Oct 10	Firehall	0	0	0	0.58	0.78	0.27
Oct 16	ER School	0	0	0	0.71	1.05	0.10
Oct 23	TownOffice	0	0	0	0.66	1.29	0.17
Oct 30	TownShop	0	0	0	0.93	1.27	0.06
Minimum					0.58	0.78	0.06
Maximum		0	0	0	1.11	1.54	0.27
Average					0.80	1.19	0.13
Count		5	5	5	5	5	5
Exceedences		0	0	0	0	0	

A minimum of 0.10 mg/L free chlorine residual **OR** 0.50 mg/L total chlorine residual is required in each bacteriological sample.

Date	Time	Comment
October 2, 2023		The valve exercise and flushing program was completed.
October 28, 2023		It was noticed that the check valve on P208 was leaking. As such, the pump was shut off and the isolation valve was closed. Gary S was notified and a quote was obtained from Wolseley for a replacement. NM

Environmental Services Analysis Report - Final

Invoice Number: 3447062	Collected Date: 30-Oct-2023 9:10 AM
Sample Location: Town Shop	Received: 30-Oct-2023 1:45 PM
Collected by: W. Matts	Reported: 31-Oct-2023 2:12 PM
Station #: SK05JF0022	Water Source: Distributed
Permit: 2574	
WHITE CITY DIST.SYSTEM	

Submitted By:

SASK WATER
225 A HELLEN DRIVE
RM OF SHERWOOD, SK
S4K 0A3

Invoice:

SASK WATER
225 A HELLEN DRIVE
RM OF SHERWOOD, SK
S4K 0A3

Analysis	Result	Unit	Sask Guideline	Test Comment	Fee
Regular Panel					23.00
Total Coliform	No Detectable	orgs/100 mL	No orgs/100 mL	1	
E. Coli	No Detectable	orgs/100 mL	No orgs/100 mL	2	

Submitter Phone Number: 306-533-1936

Emailed results to: ReginaEastResults@saskwater.com

Comments:

1. Testing result indicates that your water meets the Bacteriological standard for Canadian drinking water quality.
2. See above for comment

Please include Invoice Number with payment and remit to:

Saskatchewan Health Authority
c/o Finance
2180 23rd Avenue
Regina, Saskatchewan
S4S 0A5

Total Fees (including GST) 23.00

Tax Summary 1.10
G.S.T. (reg # 89583 0180 RT001)

Amount Received: (No Payment Received) 0.00

Balance Due upon receipt of invoice.

Balance Owed	\$23.00
---------------------	----------------

Contact Us:

Result Interpretation: Please contact your EPO for advice or phone 306-535-4347
Billing Inquiries: Phone: 1-833-989-5353, Email: shaar@saskhealthauthority.ca

The following data was provided by the submitter. The Environmental Services Lab does not guarantee the accuracy of the results.

Free Chlorine: 0.93	Total Chlorine: 1.27	Turbidity: 0.06
---------------------	----------------------	-----------------

Environmental Services Analysis Report - Final

Invoice Number: 3446541	Collected Date: 23-Oct-2023 2:15 PM
Sample Location: Town Office	Received: 24-Oct-2023 9:30 AM
Collected by: B. Stevenson	Reported: 25-Oct-2023 9:17 AM
Station #: SK05JF0022	Water Source: Distributed
Permit: 2574	
WHITE CITY DIST.SYSTEM	

Submitted By: SASK WATER 225 A HELLEN DRIVE RM OF SHERWOOD, SK S4K 0A3	Invoice: SASK WATER 225 A HELLEN DRIVE RM OF SHERWOOD, SK S4K 0A3
-------------------------------------------------------------------------------------------	--------------------------------------------------------------------------------------

Analysis	Result	Unit	Sask Guideline	Test Comment	Fee
Regular Panel					23.00
Total Coliform	No Detectable	orgs/100 mL	No orgs/100 mL	1	
E. Coli	No Detectable	orgs/100 mL	No orgs/100 mL	2	

Submitter Phone Number: 306-533-1936 **Emailed results to:** ReginaEastResults@saskwater.com

Comments:

1. Testing result indicates that your water meets the Bacteriological standard for Canadian drinking water quality.
2. See above for comment

Please include Invoice Number with payment and remit to:	Saskatchewan Health Authority c/o Finance 2180 23rd Avenue Regina, Saskatchewan S4S 0A5	Total Fees (including GST) 23.00	
		Tax Summary 1.10 G.S.T. (reg # 89583 0180 RT001)	
		Amount Received: (No Payment Received) 0.00	

Balance Due upon receipt of invoice.

Balance Owed	\$23.00
---------------------	----------------

Contact Us:

Result Interpretation: Please contact your EPO for advice or phone 306-535-4347
Billing Inquiries: Phone: 1-833-989-5353, Email: shaar@saskhealthauthority.ca

The following data was provided by the submitter. The Environmental Services Lab does not guarantee the accuracy of the results.

Free Chlorine: 0.66	Total Chlorine: 1.29	Turbidity: 0.17
---------------------	----------------------	-----------------

Environmental Services Analysis Report - Final

Invoice Number: 3444966	Collected Date: 02-Oct-2023 10:45 AM
Sample Location: Town Shop	Received: 02-Oct-2023 2:54 PM
Collected by: W. Matts	Reported: 03-Oct-2023 2:12 PM
Station #: SK05JF0022	Water Source: Distributed
Permit: 2574	
WHITE CITY DIST.SYSTEM	

Submitted By:	Invoice:
SASK WATER	SASK WATER
225 A HELLEN DRIVE	225 A HELLEN DRIVE
RM OF SHERWOOD, SK	RM OF SHERWOOD, SK
S4K 0A3	S4K 0A3

Analysis	Result	Unit	Sask Guideline	Test Comment	Fee
Regular Panel					23.00
Total Coliform	No Detectable	orgs/100 mL	No orgs/100 mL	1	
E. Coli	No Detectable	orgs/100 mL	No orgs/100 mL	2	

Submitter Phone Number: 306-533-1936 **Emailed results to:** ReginaEastResults@saskwater.com

Comments:

1. Testing result indicates that your water meets the Bacteriological standard for Canadian drinking water quality.
2. See above for comment

Please include Invoice Number with payment and remit to:	Saskatchewan Health Authority c/o Finance 2180 23rd Avenue Regina, Saskatchewan S4S 0A5	<table border="0" style="width: 100%;"> <tr> <td>Total Fees (including GST)</td> <td style="text-align: right;">23.00</td> </tr> <tr> <td>Tax Summary</td> <td style="text-align: right;">1.10</td> </tr> <tr> <td style="padding-left: 20px;">G.S.T. (reg # 89583 0180 RT001)</td> <td></td> </tr> <tr> <td>Amount Received: (No Payment Received)</td> <td style="text-align: right;">0.00</td> </tr> </table>	Total Fees (including GST)	23.00	Tax Summary	1.10	G.S.T. (reg # 89583 0180 RT001)		Amount Received: (No Payment Received)	0.00
Total Fees (including GST)	23.00									
Tax Summary	1.10									
G.S.T. (reg # 89583 0180 RT001)										
Amount Received: (No Payment Received)	0.00									

Balance Due upon receipt of invoice.

Balance Owed	\$23.00
---------------------	----------------

Contact Us:

Result Interpretation: Please contact your EPO for advice or phone 306-535-4347
Billing Inquiries: Phone: 1-833-989-5353, Email: shaar@saskhealthauthority.ca

The following data was provided by the submitter. The Environmental Services Lab does not guarantee the accuracy of the results.

Free Chlorine: 1.11	Total Chlorine: 1.54	Turbidity: 0.07
---------------------	----------------------	-----------------

Environmental Services Analysis Report - Final

Invoice Number: 3445495	Collected Date: 10-Oct-2023 10:00 AM	
Sample Location: Firehall	Received: 10-Oct-2023 12:27 PM	
Collected by: W. Matts	Reported: 11-Oct-2023 2:08 PM	Permit: 2574
Station #: SK05JF0022	Water Source: Distributed	WHITE CITY DIST.SYSTEM

Submitted By: SASK WATER 225 A HELLEN DRIVE RM OF SHERWOOD, SK S4K 0A3	Invoice: SASK WATER 225 A HELLEN DRIVE RM OF SHERWOOD, SK S4K 0A3
-------------------------------------------------------------------------------------------	--------------------------------------------------------------------------------------

Analysis	Result	Unit	Sask Guideline	Test Comment	Fee
Regular Panel					23.00
Total Coliform	No Detectable	orgs/100 mL	No orgs/100 mL	1	
E. Coli	No Detectable	orgs/100 mL	No orgs/100 mL	2	

Submitter Phone Number: 306-533-1936 **Emailed results to:** ReginaEastResults@saskwater.com

Comments:

1. Testing result indicates that your water meets the Bacteriological standard for Canadian drinking water quality.
2. See above for comment

Please include Invoice Number with payment and remit to:	Saskatchewan Health Authority c/o Finance 2180 23rd Avenue Regina, Saskatchewan S4S 0A5	Total Fees (including GST) 23.00	
		Tax Summary 1.10 G.S.T. (reg # 89583 0180 RT001)	
		Amount Received: (No Payment Received) 0.00	

Balance Due upon receipt of invoice.

Balance Owed	\$23.00
---------------------	----------------

Contact Us:

Result Interpretation: Please contact your EPO for advice or phone 306-535-4347
Billing Inquiries: Phone: 1-833-989-5353, Email: shaar@saskhealthauthority.ca

The following data was provided by the submitter. The Environmental Services Lab does not guarantee the accuracy of the results.

Free Chlorine: 0.58	Total Chlorine: 0.78	Turbidity: 0.27
---------------------	----------------------	-----------------

Environmental Services Analysis Report - Final

Invoice Number: 3445987	Collected Date: 16-Oct-2023 9:40 AM	
Sample Location: White City ER School	Received: 16-Oct-2023 12:39 PM	
Collected by: W. Matts	Reported: 17-Oct-2023 3:12 PM	Permit: 2574
Station #: SK05JF0022	Water Source: Distributed	WHITE CITY DIST.SYSTEM

Submitted By: SASK WATER 225 A HELLEN DRIVE RM OF SHERWOOD, SK S4K 0A3	Invoice: SASK WATER 225 A HELLEN DRIVE RM OF SHERWOOD, SK S4K 0A3
-------------------------------------------------------------------------------------------	--------------------------------------------------------------------------------------

Analysis	Result	Unit	Sask Guideline	Test Comment	Fee
Regular Panel					23.00
Total Coliform	No Detectable	orgs/100 mL	No orgs/100 mL	1	
E. Coli	No Detectable	orgs/100 mL	No orgs/100 mL	2	

Submitter Phone Number: 306-533-1936 **Emailed results to:** ReginaEastResults@saskwater.com

Comments:

1. Testing result indicates that your water meets the Bacteriological standard for Canadian drinking water quality.
2. See above for comment

Please include Invoice Number with payment and remit to:	Saskatchewan Health Authority c/o Finance 2180 23rd Avenue Regina, Saskatchewan S4S 0A5	Total Fees (including GST) 23.00 Tax Summary 1.10 G.S.T. (reg # 89583 0180 RT001)
----------------------------------------------------------	----------------------------------------------------------------------------------------------------------------------------------------	-------------------------------------------------------------------------------------------------------------------------------------------------------------------

Amount Received: (No Payment Received) 0.00

Balance Due upon receipt of invoice.

Balance Owed	\$23.00
---------------------	----------------

Contact Us:

Result Interpretation: Please contact your EPO for advice or phone 306-535-4347
Billing Inquiries: Phone: 1-833-989-5353, Email: shaar@saskhealthauthority.ca

The following data was provided by the submitter. The Environmental Services Lab does not guarantee the accuracy of the results.

Free Chlorine: 0.71	Total Chlorine: 1.05	Turbidity: 0.10
---------------------	----------------------	-----------------