

White City WTP										
June 2023	Raw Volume (m3) Avg	Treated Volume (m3) Avg	Treated Free Chlorine (mg/L) Min	Treated Total Chlorine (mg/L) Min	Treated Free Chlorine (Analyser) (mg/L) Min	Treated pH (Analyser) (pH units) Avg	Treated Turbidity (NTU) Max	Treated Turbidity (Analyser) (NTU) Max	Treated Iron (mg/L) Avg	Treated Manganese (mg/L) Avg
Jun 01	1573	1446	0.97	1.25	0.90	7.06	0.04	0.018		0.035
02	1349	1214	0.82	1.18	0.87	7.06	0.07	0.031		0.029
03	632	585	0.86	1.20	0.82	7.04	0.08	0.031		0.020
04	1579	1459	0.88	1.15	0.79	7.03	0.08	0.026		0.033
05	1703	1734	0.75	1.17	0.80	7.01	0.09	0.019		0.022
06	1594	1378	0.94	1.20	0.79	7.00	0.11	0.041	0.02	0.039
07	1381	1301	0.69	1.00	0.70	6.99	0.10	0.036		0.035
08	1142	1017	0.67	0.84	0.67	7.00	0.12	0.030		0.040
09	1262	1251	0.74	1.06	0.71	7.04	0.09	0.030		0.021
10	1231	1269	0.87	1.12	0.82	7.04	0.11	0.022		0.033
11	1528	1380	0.90	1.27	0.86	7.04	0.05	0.018		0.031
12	1881	1891	0.90	1.30	0.92	7.03	0.07	0.014	0.00	0.023
13	1620	1561	0.89	1.29	0.92	7.03	0.04	0.009		0.008
14	2155	2067	0.91	1.27	0.91	7.03	0.08	0.016		0.023
15	1381	1186	0.87	1.11	0.88	7.04	0.10	0.013		0.026
16	1484	1443	0.79	1.24	0.85	7.04	0.10	0.021		0.025
17	1417	1286	0.82	1.21	0.83	7.04	0.10	0.019		0.026
18	2202	2024	0.86	1.25	0.83	7.04	0.09	0.017		0.032
19	1206	1171	0.84	1.20	0.81	7.04	0.09	0.014	0.00	0.024
20	1292	1249	0.86	1.17	0.79	7.06	0.11	0.016		0.024
21	1164	1096	0.81	1.10	0.80	7.06	0.09	0.013		0.041
22	1305	1251	0.82	1.13	0.80	7.06	0.06	0.100		0.018
23	1987	1989	0.85	1.11	0.84	7.06	0.05	0.017		0.029
24	1323	1275	0.92	1.31	0.95	7.05	0.08	0.020		0.030
25	1842	1752	1.07	1.46	1.10	7.06	0.05	0.015		0.024
26	2270	2332	1.06	1.50	1.14	7.06	0.05	0.009	0.03	0.034
27	1779	1621	1.11	1.44	1.05	7.06	0.09	0.019		0.017
28	2493	2387	1.01	1.42	1.01	7.04	0.06	0.009		0.025
29	1635	1614	1.05	1.42	1.01	7.06	0.08	0.031		0.040
30	2100	1965	1.06	1.50	1.07	7.06	0.07	0.016		0.041
Minimum	632	585	0.67	0.84	0.67	6.99	0.04	0.009	0.00	0.008
Maximum	2493	2387	1.11	1.50	1.14	7.06	0.12	0.100	0.03	0.041
Average	1584	1506	0.89	1.23	0.87	7.04	0.08	0.023	0.01	0.028
Count			30	30	30	30	30	30	4	30
Total	47510	45194								
95th Percentile							0.11	0.036		
Exceedences			0		0					

If there is more than one per day reading for free chlorine residual, the daily minimum is reported.

If there is more than one per day reading for turbidity, the daily maximum is reported.

White City WTP - Bacteriological (Raw Water)			
June 2023	Total Coliform (Count)	E. Coli (Count)	Background Bacteria (Count)
Jun 01			

White City WTP - Bacteriological						
June 2023	Total Coliform (Count)	E. Coli (Count)	Background Bacteria (Count)	Free Chlorine (mg/L)	Total Chlorine (mg/L)	Turbidity (NTU)
Jun 05	0	0	0	0.75	1.17	0.09
Jun 12	0	0	0	0.90	1.30	0.07
Jun 19	0	0	0	0.84	1.20	0.09
Jun 26	0	0	0	1.06	1.50	0.05
Minimum				0.75	1.17	0.05
Maximum	0	0	0	1.06	1.50	0.09
Average				0.89	1.29	0.08
Count	4	4	4	4	4	4
Exceedences	0	0	0	0	0	

A minimum of 0.10 mg/L free chlorine residual **OR** 0.50 mg/L total chlorine residual is required in each bacteriological sample.

White City Distribution - Bacteriological							
June 2023	Sampling Location ()	Total Coliform (Count)	E. Coli (Count)	Background Bacteria (Count)	Free Chlorine (mg/L)	Total Chlorine (mg/L)	Turbidity (NTU)
Jun 05	WC School	0	0	0	0.83	1.18	0.10
Jun 12	JamesonHydrant	0	0	0	0.65	0.89	2.97
Jun 19	ER School	0	0	0	0.76	0.99	0.08
Jun 26	TownShop	0	0	0	1.01	1.42	0.06
Minimum					0.65	0.89	0.06
Maximum		0	0	0	1.01	1.42	2.97
Average					0.81	1.12	0.80
Count		4	4	4	4	4	4
Exceedences		0	0	0	0	0	

A minimum of 0.10 mg/L free chlorine residual **OR** 0.50 mg/L total chlorine residual is required in each bacteriological sample.

Date	Time	Comment
June 2023		Town of White City irrigation pump losing prime continuously. Needs some new plumbing and a pump rebuild.

Environmental Services Analysis Report - Final

Invoice Number: 3435391	Collected Date: 05-Jun-2023 11:55 AM	
Sample Location: WC School	Received: 06-Jun-2023 9:11 AM	
Collected by: B. Stevenson	Reported: 07-Jun-2023 9:43 AM	Permit: 2574
Station #: SK05JF0022	Water Source: Distributed	WHITE CITY DIST.SYSTEM

Submitted By: SASK WATER 225 A HELLEN DRIVE RM OF SHERWOOD, SK S4K 0A3	Invoice: SASK WATER 225 A HELLEN DRIVE RM OF SHERWOOD, SK S4K 0A3
---	--

Analysis	Result	Unit	Sask Guideline	Test Comment	Fee
Regular Panel					23.00
Total Coliform	No Detectable	orgs/100 mL	No orgs/100 mL	1	
E. Coli	No Detectable	orgs/100 mL	No orgs/100 mL	2	

Submitter Phone Number: 306-533-1936 **Emailed results to:** ReginaEastResults@saskwater.com

Comments:

1. Testing result indicates that your water meets the Bacteriological standard for Canadian drinking water quality.
2. See above for comment

Please include Invoice Number with payment and remit to:	Saskatchewan Health Authority c/o Finance 2180 23rd Avenue Regina, Saskatchewan S4S 0A5	Total Fees (including GST) 23.00 Tax Summary 1.10 G.S.T. (reg # 89583 0180 RT001)
--	--	---

Amount Received: (No Payment Received) 0.00

Balance Due upon receipt of invoice.

Balance Owed	\$23.00
---------------------	----------------

Contact Us:

Result Interpretation: Please contact your EPO for advice or phone 306-535-4347
Billing Inquiries: Phone: 1-833-989-5353, Email: shaar@saskhealthauthority.ca

The following data was provided by the submitter. The Environmental Services Lab does not guarantee the accuracy of the results.

Free Chlorine: 0.83	Total Chlorine: 1.18	Turbidity: 0.10
---------------------	----------------------	-----------------

Environmental Services Analysis Report - Final

Invoice Number: 3435990	Collected Date: 12-Jun-2023 11:45 AM	
Sample Location: Jamison Hydrant	Received: 12-Jun-2023 2:43 PM	
Collected by: N. Matts	Reported: 13-Jun-2023 2:13 PM	Permit: 2574
Station #: SK05JF0022	Water Source: Distributed	WHITE CITY DIST.SYSTEM

Submitted By: SASK WATER 225 A HELLEN DRIVE RM OF SHERWOOD, SK S4K 0A3	Invoice: SASK WATER 225 A HELLEN DRIVE RM OF SHERWOOD, SK S4K 0A3
---	--

Analysis	Result	Unit	Sask Guideline	Test Comment	Fee
Regular Panel					23.00
Total Coliform	No Detectable	orgs/100 mL	No orgs/100 mL	1	
E. Coli	No Detectable	orgs/100 mL	No orgs/100 mL	2	

Submitter Phone Number: 306-533-1936 **Emailed results to:** ReginaEastResults@saskwater.com

Comments:

1. Testing result indicates that your water meets the Bacteriological standard for Canadian drinking water quality.
2. See above for comment

Please include Invoice Number with payment and remit to:	Saskatchewan Health Authority c/o Finance 2180 23rd Avenue Regina, Saskatchewan S4S 0A5	Total Fees (including GST)	23.00
		Tax Summary G.S.T. (reg # 89583 0180 RT001)	1.10
		Amount Received: (No Payment Received)	0.00

Balance Due upon receipt of invoice.

Balance Owed	\$23.00
---------------------	----------------

Contact Us:

Result Interpretation: Please contact your EPO for advice or phone 306-535-4347
Billing Inquiries: Phone: 1-833-989-5353, Email: shaar@saskhealthauthority.ca

The following data was provided by the submitter. The Environmental Services Lab does not guarantee the accuracy of the results.

Free Chlorine: .65	Total Chlorine: .89	Turbidity: 2.97
--------------------	---------------------	-----------------

Environmental Services Analysis Report - Final

Invoice Number: 3436507	Collected Date: 19-Jun-2023 10:40 AM	
Sample Location: Emerald Ridge School	Received: 19-Jun-2023 3:25 PM	
Collected by: N. Matts	Reported: 20-Jun-2023 2:24 PM	Permit: 2574
Station #: SK05JF0022	Water Source: Distributed	WHITE CITY DIST.SYSTEM

Submitted By:	Invoice:
SASK WATER	SASK WATER
225 A HELLEN DRIVE	225 A HELLEN DRIVE
RM OF SHERWOOD, SK	RM OF SHERWOOD, SK
S4K 0A3	S4K 0A3

Analysis	Result	Unit	Sask Guideline	Test Comment	Fee
Regular Panel					23.00
Total Coliform	No Detectable	orgs/100 mL	No orgs/100 mL	1	
E. Coli	No Detectable	orgs/100 mL	No orgs/100 mL	2	

Submitter Phone Number: 306-533-1936 **Emailed results to:** ReginaEastResults@saskwater.com

Comments:

1. Testing result indicates that your water meets the Bacteriological standard for Canadian drinking water quality.
2. See above for comment

Please include Invoice Number with payment and remit to:	Saskatchewan Health Authority c/o Finance 2180 23rd Avenue Regina, Saskatchewan S4S 0A5	Total Fees (including GST)	23.00
		Tax Summary	1.10
		G.S.T. (reg # 89583 0180 RT001)	

Amount Received: (No Payment Received) 0.00

Balance Due upon receipt of invoice.

Balance Owed	\$23.00
---------------------	----------------

Contact Us:

Result Interpretation: Please contact your EPO for advice or phone 306-535-4347
Billing Inquiries: Phone: 1-833-989-5353, Email: shaar@saskhealthauthority.ca

The following data was provided by the submitter. The Environmental Services Lab does not guarantee the accuracy of the results.

Free Chlorine: .76	Total Chlorine: .99	Turbidity: .08
--------------------	---------------------	----------------

Environmental Services Analysis Report - Final

Invoice Number: 3437079	Collected Date: 26-Jun-2023 11:45 AM	
Sample Location: Town Shop	Received: 26-Jun-2023 3:52 PM	
Collected by: Jeff Hindle	Reported: 27-Jun-2023 2:26 PM	Permit: 2574
Station #: SK05JF0022	Water Source: Distributed	WHITE CITY DIST.SYSTEM

Submitted By: SASK WATER 225 A HELLEN DRIVE RM OF SHERWOOD, SK S4K 0A3	Invoice: SASK WATER 225 A HELLEN DRIVE RM OF SHERWOOD, SK S4K 0A3
---	--

Analysis	Result	Unit	Sask Guideline	Test Comment	Fee
Regular Panel					23.00
Total Coliform	No Detectable	orgs/100 mL	No orgs/100 mL	1	
E. Coli	No Detectable	orgs/100 mL	No orgs/100 mL	2	

Submitter Phone Number: 306-533-1936 **Emailed results to:** ReginaEastResults@saskwater.com

Comments:

1. Testing result indicates that your water meets the Bacteriological standard for Canadian drinking water quality.
2. See above for comment

Please include Invoice Number with payment and remit to:	Saskatchewan Health Authority c/o Finance 2180 23rd Avenue Regina, Saskatchewan S4S 0A5	Total Fees (including GST)	23.00
		Tax Summary G.S.T. (reg # 89583 0180 RT001)	1.10
		Amount Received: (No Payment Received)	0.00

Balance Due upon receipt of invoice.

Balance Owed	\$23.00
---------------------	----------------

Contact Us:

Result Interpretation: Please contact your EPO for advice or phone 306-535-4347
Billing Inquiries: Phone: 1-833-989-5353, Email: shaar@saskhealthauthority.ca

The following data was provided by the submitter. The Environmental Services Lab does not guarantee the accuracy of the results.

Free Chlorine: 1.01	Total Chlorine: 1.42	Turbidity: 0.06
---------------------	----------------------	-----------------